

CORRIGENDUM I

**Name of the Work. "Construction of proposed Guest House at Raichak,
District- 24 Pargana (S)" .**

NIT NO.:_ SMPK/KDS/CIV /T/2702/61 Dt. 14.09.2022

In continuation to the above mentioned NIT No. following is further notified.

Item	In place of	To be read as
Scope of Work TECHNICAL SPECIFICATIONS of Electricals Works List of Approved Makes Table Sl. No.3	PVC Copper wire for internal wiring Finolex/Havells/KEI/Polycab/Gloster/ any other reputed make.	FRLS PVC Copper wire for internal wiring Finolex/Havells/KEI/Polycab/Gloster/ Bonton " any other reputed make.

All other terms and conditions remain unchanged as per original.

Superintending Engineer (Contract)
For मुख्य अभियंता / Chief Engineer
SYAMA PRASAD MOOKERJEE PORT, KOLKATA