

SyamaPrasad MookerjeePort,Kolkata
Mechanical & Electrical Engineering Department

Minutes of Pre-bid meeting held on 20.03.2023 for “Electrical Installation work for Lift, Toilet Block and other allied works at adjacent building to Fairlie Warehouse”

NIT No.: SMP/KDS/Mech/DC-I/ADV/631 dated 13.03.2023

Prospective bidders present in the pre-bid meeting are –

- (1) M/s. Expert Electrical
- (2) M/s. H. S. Enterprise
- (3) M/s. Biswakarma Electric
- (4) M/s Modern Software Systems

Pursuant to the discussion held with the prospective bidders at the time of pre-bid Meeting, the following are recorded:

- i. No issues regarding the commercial points have been raised by the Prospective bidders.
- ii. Query regarding the detailed technical specification of the decorative heritage pole & Luminaire was raised.

Reply: -

| SL.No. | Description | Clarification/Corrigendum |
|---------------|---|---|
| BOQ no. 71 | Supply & Delivery of Aesthetic Heritage Lamp Post of 5 meters high with a set of suitable nuts and bolts. | Supply & Delivery of Decorative casting Pole of 4 or 5 meters in height, PU painted with set of suitable nuts and bolts. (Design as approved by EIC) |
| BOQ no. 72 | Supply, Delivery, Installation, and Commissioning of Aesthetic Architectural Heritage Design Luminaire with all accessories suitable for the above heritage lamp post | Supply, Delivery, Installation, and Commissioning of Aesthetic Heritage Design Landscape Luminaire with lamp with the following specifications:- Wattage= 60W to 70 W (2800 System Lumens or more), suitable for lamp post or pole mounting, 3000K, CRI≥80, THD≤10%, IP65 or more, IK07 or more, die-cast aluminum post top luminaire with diffuser to provide glare-free Light, Powered by built-in, electronic LED driver with Output Short / Open Circuit protection, Over Voltage protection, Surge Voltage protection upto 10 kV with external SPD & other reliability tests as per IS 15885 Part- 2/Sec 13.(Design as approved by EIC) |

- iii. All other terms and conditions of the NIT remain unchanged.
- iv. This minute is to be considered as a part of the NIT.

Chief Mechanical Engineer