



SYAMA PRASAD MOOKERJEE PORT, KOLKATA
(Erstwhile Kolkata Port Trust)

MECHANICAL & ELECTRICAL ENGINEERING DEPARTMENT

Minutes of pre-bid meeting held on 30.03.2023 for “Electrical work for installation of 1 no. Compressor and 3 nos. Electric Arc Welding Machine providing TXR Facility at EJC Yard”

Notice Inviting Tender No.: SMP/KDS/Mech/DC-I/ADV/632 dated 20.03.2023

No representative of any firm has attended the site inspection followed by pre-bid meeting.

Further, “Conductor : Stranded Copper, comply to IS : 8130-1984 or latest amendment if any” as mentioned in BOQ Sl. No. 1(a), 3(a) & 5(a) at Page – 30 & 31 of NIT is to be read as “Conductor : Stranded Aluminium, comply to IS : 8130-1984 or latest amendment if any”.

All other terms and conditions of the NIT shall remain unchanged.

Chief Mechanical Engineer